

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:206 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

DESIGN: Model TeleSMART Messaging Module. Unit receives synthesized voice messages over the phone regarding the status of the control unit. Unit must be mounted inside the control unit or within a separate listed enclosure. Unit is suitable for use with separately listed Ademco fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10.5-14.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

12-13-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 7, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager